


THIS COPY IS PROVIDED ON A RESTRICTED BASIS AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF PANDUIT CORP.



PANDUIT P/N	"A"
VS-AVT-CABLE-02	2 FT
VS-AVT-CABLE-04	4 FT
VS-AVT-CABLE-08	8 FT
VS-AVT-CABLE-16	16 FT
VS-AVT-CABLE-20	20 FT
VS-AVT-CABLE-30	30 FT

NOTES:

1. AVT DEVICE SYSTEM CABLE PROVIDES POWER AND SIGNAL BETWEEN THE INDICATOR MODULE AND THE VDD ISOLATION MODULE.
2. THIS CABLE SHOULD NOT BE USED FOR ETHERNET COMMUNICATION.
3. SEE PRICE LIST FOR CURRENT PRICE AND ORDERING INFORMATION.

PRODUCT SPEC	PACKAGING SPEC
PART NUMBER SEE TABLE	WORK INSTRUCTION
INSPECTION INSTRUCTION NUMBER	FMEA & CONTROL PLAN NUMBER

TITLE AVT SYSTEM CABLE CUSTOMER DRAWING	
ITEM REVISION NAME 14I216AR/06	PANDUIT
DATASET FILE NAME 14I216AR_DC/06	
UNLESS OTHERWISE SPECIFIED, DIMENSIONAL TOLERANCES ARE: IN [mm]	
.x ± .1 [2.54]	.xxx ± .005 [.127]
.xx ± .01 [.25]	ANGLES ± 5 °
THIRD ANGLE PROJECTION	
MATERIAL: RoHS COMPLIANT	
DRAWING NUMBER: 14I216AR_DC	

1	10/2/17	DFA	CLW	MSAD	ADDED 4, 16, 20 AND 30 FT CABLES TO TABLE	GAECN05158
0	5/25/17	DFA	CLW	MSAD	INITIAL RELEASE	GAECN05094

REV	DATE	BY	CHK	APR	DESCRIPTION	ECN
1	5/25/17	DFA	CLW	MSAD	ADDED 4, 16, 20 AND 30 FT CABLES TO TABLE	GAECN05158
0	5/25/17	DFA	CLW	MSAD	INITIAL RELEASE	GAECN05094

DRAWN BY DFA	DATE 5/25/17	CHK MSAD	SCALE NONE	SHT 1 OF 1	SIZE A
------------------------	------------------------	--------------------	----------------------	------------	------------------

D10100DA/20